## 8.3.3.3.1\*

Required fire door assemblies shall be installed, inspected, tested, and maintained in accordance with NFPA 80.

## N A.8.3.3.3.1

Where a door or door frame is not required to be fire protection rated and is equipped with a fire protection listing label, the door and the door frame is not required to comply with NFPA 80.