

Committee Action:

None-PC (Public Comment)

Committee Reason: Comments discussed but no new action was taken by the committee. See Reason statement from CAH #1 action.

FS63-24

FS65-24

Committee Action:

As Modified by Committee (AMC2)

Approved Comments: Comment 1

Committee Modification:

Modify Comment as follows:

2024 International Building Code

Revise as follows:

716.2.6.1 Door closing. *Fire doors* shall be latching and self- or automatic-closing in accordance with this section.

Exceptions:

1. *Fire doors* located in common walls separating *dwelling units* or *sleeping units* in Group R-1 shall be permitted without automatic- or *self-closing* devices.
2. In Group I-1, Condition 2, *fire doors* located in corridors and serving sleeping units that do not include a cooktop or range shall be permitted without automatic- or self-closing devices.
3. The elevator car doors and the associated elevator hoistway doors at the floor level designated for recall in accordance with Section 3003.2 shall be permitted to remain open during Phase I emergency recall operation.
4. Fire doors required solely for compliance with ICC 500 shall not be required to be *self-closing* or automatic-closing.

Committee Reason: The committee concluded that the modification was a good clean-up to the text by removing corridors from the proposed text. The committee approved the comment due to the fact that the comment addressed the issues in the original proposal by clarifying exception 2. (Vote: 10-0)

FS65-24

FS67-24

Committee Action:

None-PC (Public Comment)

Committee Reason: Comments discussed but no new action was taken by the committee. See Reason statement from CAH #1 action.

FS67-24

FS69-24